



TYPICAL SERVICES PROTECTION DETAIL




PIPE / DUCT TRENCH - REINSTATEMENT IN EXISTING PUBLIC ROAD
SCALE 1:25



PIPE / DUCT TRENCH - REINSTATEMENT IN EXISTING PUBLIC FOOTPATH / OPEN SPACES
SCALE 1:25

© COPYRIGHT OF THIS DRAWING IS RESERVED BY DBFL CONSULTING ENGINEERS. NO PART SHALL BE REPRODUCED OR TRANSMITTED WITHOUT THEIR WRITTEN PERMISSION.

ON ORIGINAL



NOTES:

GENERAL NOTES:

- ALL SURFACE WATER MANHOLES AND DRAINAGE ARE TO BE CONSTRUCTED IN ACCORDANCE WITH THE REQUIREMENTS OF THE GREATER DUBLIN CODE OF PRACTICE FOR DRAINAGE WORKS.
- ALL FOUL DRAINAGE WORKS TO BE IN ACCORDANCE WITH IRISH WATER'S CODE OF PRACTICE FOR WASTEWATER SUPPLY AND WASTEWATER INFRASTRUCTURE STANDARD DETAILS.
- SURFACES FINISHES FOR CONCRETE:
 - CLASS F1 FOR ALL CONCRETE 100mm OR MORE BELOW GROUND LEVEL.
 - CLASS F3 FOR ALL EXPOSED CONCRETE ABOVE 100mm BELOW GROUND LEVEL.
- ALL EXPOSED CORNERS ON CONCRETE SHALL BE CHAMFERED WITH 25mm x 25mm CHAMFERS.
- ALL STRUCTURAL CONCRETE (HEADWALLS, RC MANHOLES, PETROL INTERCEPTOR SLABS) TO RECEIVE MC DUR 1680 (OR SIMILAR APPROVED TAR MODIFIED EPOXY RESIN) TO ALL BURIED SURFACES. TO FINISH 100mm BELOW GROUND LEVEL.
- ALL SEWERS SHALL BE PRESSURE TESTED PRIOR TO BACKFILLING.
- TYPE 1 GRANULAR MATERIAL - BROKEN STONE OR GRAVEL TO PASS 10mm SIEVE AND BE RETAINED ON 5mm SIEVE. TYPE 2 GRANULAR MATERIAL - BROKEN STONE OR GRAVEL TO PASS 10mm - 25mm SIEVE, ACCORDING TO PIPE SIZE, (SEE TABLE) AND BE RETAINED ON 5mm SIEVE.
- TYPE 3 SELECTED FILL - UNIFORM READILY COMPACTED MATERIAL FREE FROM TREE ROOTS, VEGETABLE MATTER, BUILDING DEBRIS, AND FROZEN SOIL AND EXCLUDING CLAY LUMPS RETAINED ON A 75mm SIEVE AND STONES RETAINED ON A 37.5mm SIEVE.
- ALL LADDERS, RUNGS, SAFETY CHAINS etc SHALL BE HOT DIPPED GALVANISED TO BS 729 OR EQUIVALENT.
- ALL ROAD CONSTRUCTION MATERIALS TO COMPLY WITH NRA VOLUME 1 SPECIFICATIONS FOR ROADWORKS DATED MARCH 2011 AND SUBSEQUENT REVISIONS OF SAME. ROAD REFERENCE DETAILS TO BE AS PER NRA VOLUME 4 ROAD CONSTRUCTION DETAILS DATED JUNE 2014.
- CLAUSE 601 S.R.W. BACKFILL: UNIFORM READILY COMPACTED MATERIAL FREE FROM TREE ROOTS, VEGETABLE MATTER, BUILDING DEBRIS, AND FROZEN SOIL AND EXCLUDING CLAY LUMPS RETAINED ON A 75mm SIEVE AND STONES RETAINED ON A 37.5mm SIEVE.
- ALL PIPES TO BE BEDDED IN ACCORDANCE WITH MANUFACTURERS RECOMMENDATIONS

TYPE 2 GRANULAR MATERIAL :

| PIPE SIZE | 100% PASSING |
|--------------|--------------|
| UP TO 225mm | 10mm SIEVE |
| 225 TO 450mm | 20mm SIEVE |
| ABOVE 450mm | 25mm SIEVE |

| REV. | DATE | DESCRIPTION | BY | CHKD. |
|------|------|-------------|----|-------|
|------|------|-------------|----|-------|

PLANNING

| DESIGNED | BK | PREPARED | ICD |
|----------|----|----------|-----|
|----------|----|----------|-----|

| DATE | APR 2019 | CHECKED | DJR |
|------|----------|---------|-----|
|------|----------|---------|-----|



DUBLIN OFFICE Ormond House,
Upper Ormond Quay, Dublin 7, Ireland.
PHONE +353 1 400 4000
FAX +353 1 400 4050

WATERFORD OFFICE Unit 2, The Chandlery,
1-2 O'Connell Street, Waterford, Ireland.
PHONE +353 51 399 550
FAX +353 51 844 913

DBFL Consulting Engineers email: info@dbfl.ie url: www.dbfl.ie

PROJECT
LANDS AT CAPDOO, CLANE, CO. KILDARE

DRG. TITLE
TYPICAL DRAINAGE
DETAILS SHEET 3

CLIENT
ARDSTONE RESIDENTIAL FUND

| SCALE | 1:500 @A1 | FILE REF. | 162074-3013 |
|-------|-----------|-----------|-------------|
|-------|-----------|-----------|-------------|

| DRG. NO. | 162074-3013 |
|----------|-------------|
|----------|-------------|